

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. _____

Date : 21-8-2024

It is certified that an inspection team headed by Dr Parvati
Medical officer SDH SUNAM (Name of Officers
 with designation) from SH-SURAJ KUND Sarvhitkari vidya Mandir Sunam (Name of
 Department/Office) inspected the SH: SURAJ KUND Sarvhitkari vidya
Mandir Sunam (Name & Address of
 the School) on 21-8-2024 and found that the 20-8-2025

_____ (Name of school) has safe
 drinking water facilities for the students and members of staff of the institution and is maintaining
 the hygienic sanitation condition in the school building & the campus as per the norms
 prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 year.

Medical Officer
 Civil Hospital
 Sunam Udham Singh Wala
Parvati

Signature with Seal : _____

Name : Dr ParvatiDesignation : MO

To

SH: SURAJ KUND
Sarvhitkari Vidya Mandir
Sunam

(Name & Address of the Institution)

REGIONAL WATER TESTING LAB, SANGRUR

Prem Basti, D. C Office Road, Opposite to Punjab Gramin Bank, Sangrur
rwtlsangrur@gmail.com

Shri Surajkund Sarvhitkari Vidya Mandir
Senior Secondary English Medium School, Khadial Road, Sunam


No.: RWTL/SNG/2425/00713 Dated : 23/07/2024

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. SVM/2024-2025 Dated: 12/07/2024

As per above cited subject and reference, Please find enclosed here with the report of 2 Water sample/s received on dated 19/07/2024. It is request to fill the attached feedback form and send it back to Regional Water Testing Lab, Sangrur

D/A : Test Report



Authorized Signatory
For, Regional Water Testing Lab
Sangrur

TEST REPORT

Name & Address of Customer : Shri Surajkund Sarvhitkari Vidya Mandir Senior Secondary English Medium School, Khadial Road, Sunam			Customer Reference No.		No : SVM/2024-2025 Dated : 12/07/2024	
			Sample Submitted by			
			Date of Sample Receipt		19/07/2024	
			Analysis Starting Date		19/07/2024	
			Analysis completion Date		22/07/2024	
Discipline : Chemical Testing, Bacteriological Testing			Group: Water			
ULR No.:				Sample Type :		Treated Water
Test Report No.:		RWTL/SNG/2425/00713		Date of Issue :		23/07/2024
Registration no.:		RWTL/SNG/REG2425/01011		Condition of Sample :		Unsealed
Collection Point:		Treatment Plant (RO/CWPP/ARP/HH Purifier)		Quantity/Type of Bottle:		1000 ml / Transparent Glass Bottle
Scheme/Source:		Not Mentioned (Not Mentioned)		Location/Depth :		Svm Shishu Vatika No.1 / NA
Village :		Not Mentioned		Habitation :		Not Mentioned
Block:		Not Mentioned		District :		Sangrur
Latitude :		Not Mentioned		Longitude:		Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Iron(Fe)	BDL	1.0	No Relaxation	mg/l	Spectrophotometric Method
2	Sulphate(SO4)	BDL	200	400	mg/l	Spectrophotometric Method
3	Fluoride(F)	BDL(0.05)	1.0	1.5	mg/l	APHA 4500 F-(23rd Ed. 2017)/IS-3025 (Part-60)
4	Nitrate(NO3)	BDL(0.5)	45	No Relaxation	mg/l	Spectrophotometric Method/ APHA 4500 NO3-(23rd Ed. 2017)
5	Total Coliform(TC)	ND@35°C	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
6	E-Coli	ND@45°C	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Reviewed and Approved By



Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Sangrur

----- End of the Test Report -----

TEST REPORT

Name & Address of Customer : Shri Surajkund Sarvhitkari Vidya Mandir Senior Secondary English Medium School, Khadial Road, Sunam		Customer Reference No.	No : SVM/2024-2025 Dated : 12/07/2024
		Sample Submitted by	
		Date of Sample Receipt	19/07/2024
		Analysis Starting Date	19/07/2024
		Analysis completion Date	22/07/2024
Discipline : Chemical Testing, Bacteriological Testing		Group: Water	
ULR No.:		Sample Type:	Treated Water
Test Report No.:	RWTL/SNG/2425/00713	Date of Issue :	23/07/2024
Registration no.:	RWTL/SNG/REG2425/01012	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Transparent Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Svm School No.2 / NA
Village :	Not Mentioned	Habitation :	Not Mentioned
Block:	Not Mentioned	District :	Sangrur
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Iron(Fe)	BDL	1.0	No Relaxation	mg/l	Spectrophotometric Method
2	Sulphate(SO4)	BDL	200	400	mg/l	Spectrophotometric Method
3	Fluoride(F)	BDL(0.05)	1.0	1.5	mg/l	APHA 4500 F-(23rd Ed. 2017)/IS-3025 (Part-60)
4	Nitrate(NO3)	BDL(0.5)	45	No Relaxation	mg/l	Spectrophotometric Method/ APHA 4500 NO3-(23rd Ed. 2017)
5	Total Coliform(TC)	ND@35°C	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
6	E-Coli	ND@45°C	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Dr. Ramesh Jhorar
Quality Manager
Authorized Signatory
For, Regional Water Testing Lab
Sangrur